

CERTIFICATE OF SUITABILITY

Authorised marking: TUV025310E

CONTINUATION SHEET 2

(Modification 1)

1. Update standard from AS/NZS 4777.2:2020 to AS/NZS 4777.2:2020+A1
2. Change the license holder name to GoodWe Technologies Co., Ltd.
3. Update dc switch certificate number to AZ 69025800.
4. Update input parameters: The max. PV current increased from 12.5A x 3 to 16A x 3, max. short circuit current increased from 15A x 3 to 20A x 3.
5. Remove model GW7000-MS.

Issue Date: 14/04/2022
Expiry Date: 02/08/2026

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd



Grant Li



Acc. No. Z2870404AA
www.jas-anz.org/register